

CERTIFICATE OF COMPLIANCE

Certificate Number 20160830-S8516
Report Reference S8516-20160511
Issue Date 2016-August-30

Issued to: QSC, LLC
1675 MACARTHUR BLVD
COSTA MESA CA 92626-1440

**This is to certify that
representative samples of**

Speaker
General Signaling Equipment
Speaker Models AD-C4T, AD-C4T-LP, AD-C6T and AD-C6T-LP are suitable for indoor/outdoor damp use and air handling and plenum spaces.
Speaker Models AD-P4T and AD-P6T Pendant Speakers, suitable for indoor/outdoor damp use


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1480, Speakers for Fire Alarm, Emergency, and Commercial and Professional Use
UL 1480A, Speakers for Commercial and Professional Use
CSA C22.2 No. 205-12, Signal Equipment

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

